Approval Number 260755045
Test Report: PB2026002169 & PB2026002171

Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

31st July 2026

[redacted]

WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYBUTYLENE **5200**

[redacted] 2026'. Extruded, multi-layered barrier pipes with a white OR grey coloured PB inner layer, EVOH barrier layer and a white OR grey coloured PB outer layer. For use with water up to 85°C.

APPROVAL NUMBER: **260755045**
APPROVAL HOLDER: [redacted]

The Scheme reserves the right to review approval.
Approval 260755045 is valid between July 2026 and July 2031

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

Ian Hughes
WRAS Approvals Manager